

Attestation of Conformity for Components

We, Roxtec International AB, declare under sole responsibility that the products to which this declaration relates is in accordance with the provisions of the Directive 2014/34/EU
The products complies following harmonized standards:

EN IEC 60079-0:2018, EN IEC 60079-7:2015/A1:2018 and EN 60079-31:2014

The standards listed in the EC-Type Examination Certificate are no longer harmonized, the revised (now harmonized) standards have been compared to the standards used for certification purposes and no changes in the "state of the art" apply to the equipment.

Cable Transit Device:

G...W Ex, S Ex, S...SO... Ex, SRC Ex, SK Ex, S BTB Ex, S...WM Ex,
SF...W Ex, R...W Ex, RO...W Ex, RS...W Ex and B...C Ex

Certificate:

No. 12ATEX1279U issued by Nemko (id.no. 0470), based on EC-type Examination performed by them.
No. SP03ATEX7102 issued by RISE - Research Institutes of Sweden (id.no 0402), based on assessment of the quality system performed by them.

Characteristics and how the components shall be incorporated into equipment:
Stated in EC-type Examination certificate and the instructions which accompany the components.

Marking:

  II 2G Ex e IIC Gb
  II 2D Ex tb IIIC Db

Karlskrona 2021-02-11

Roxtec International AB
Box 540
S-371 23 Karlskrona
SWEDEN

Jörgen Akesson
Explosion Protection Manager



EU Declaration of Conformity

We, Roxtec International AB, declare under sole responsibility that the products to which this declaration relates is in accordance with the provisions of the Directive 2014/34/EU.
The products complies with following harmonized standards:

EN IEC 60079-0:2018, EN IEC 60079-7:2015/A1:2018 and EN 60079-31:2014

The standards listed in the EC-Type Examination Certificate are no longer harmonized, the revised (now harmonized) standards have been compared to the standards used for certification purposes and no changes in the "state of the art" apply to the equipment.





Cable Transit Device:

CF 16 Ex, CF 8/32 Ex, G Ex, G BG Ex, SF Ex, SF BG Ex, SFX...B Ex, R...B Ex, RO...B Ex,
RS...B Ex, B...B Ex and C RS T- Ex

Certificate:

No. 12ATEX1278X issued by Nemko (id.no. 0470), based on EC-Type Examination performed by them.
No. SP03ATEX7102 issued by RISE - Research Institutes of Sweden (id.no 0402), based on assessment of the quality system performed by them.

Marking:

  II 2G Ex e IIC Gb
  II 2D Ex tb IIIC Db

Karlskrona 2021-02-11

Roxtec International AB
Box 540
SE-371 23 Karlskrona
SWEDEN

Jörgen Akesson
Explosion Protection Manager



EU Declaration of Conformity

We, Roxtec International AB, declare under sole responsibility that the products to which this declaration relates is in accordance with the provisions of the Directive 2014/34/EU. The products complies with following harmonized standards:

EN IEC 60079-0:2018, EN IEC 60079-7:2015/A1:2018 and EN 60079-31:2014

The standard EN 60079-7:2015 listed in the EC-Type Examination Certificate are no longer harmonized. The revised (now harmonized) EN IEC 60079-7:2015/A1:2018 have been compared to the standard used for certification purposes and no changes in the "state of the art" apply to the equipment.

Cable Transit Device:





HD 16 Ex, HD 24 Ex, HD 32 Ex, HDLC Ex

Certificate:

No.15 ATEX6419X issued by Presafe (id. No 2460), based on EC-Type Examination performed by them.

No. SP03ATEX7102 issued by RISE - Research Institutes of Sweden (id.no 0402), based on assessment of the quality system performed by them.

Marking:

 0402  II 2G Ex eb IIC Gb
 0402  II 2D Ex tb IIC Db

Karlskrona 2021-02-11
Roxtec International AB
Box 540
SE-371 23 Karlskrona
SWEDEN

Jörgen Akesson
Explosion Protection Manager



Roxtec International AB
Box 540, 371 23 Karlskrona, SWEDEN
PHONE +46 455 36 67 00, FAX +46 455 820 12
EMAIL info@roxtec.com, www.roxtec.com