

Certificate of Compliance

Certificate Number 20111123-E209828
Report Reference 20010330-E209828
Issue Date 2011-NOVEMBER-23

Page 1 of 1



Issued to: ROXTEC INTERNATIONAL AB
VERKO INDUSTRIOMRADE
ROMBVAGEN 2
371 23 KARLSKRONA SWEDEN

*This is to certify that
representative samples of*

COMPONENT - INDUSTRIAL CONTROL PANELS



Cabinet Seal CF-8, CF-32, CF-16, EMC Cabinet Seal CF 8, CF 16, CF 32, Cabinet Seal CRST followed by 25, 31, 43 or 50, Roxgland RG M63 followed by 1, 4 or 9, EzEntry series, Cat. No. 4 mini, 4 10, 16, 24 32, EMC Cabinet Seal, Cat. No. COMSEAL followed by 10, 12, 15, 16, 30, or 32, followed by EMC, Cabinet Seal, Cat. No. COMSEAL, followed by 10, 12, 15, 16, 30, or 32.

Have been investigated by Underwriters Laboratories in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: Industrial Control Equipment, UL 508
Industrial Control Equipment, CSA C22.2 NO. 14-10

Additional Information: See UL On-line Certification Directory at WWW.UL.COM for additional information.

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Look for the UL Recognized Component Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus>

ModelsSection Report Date

USR, CNR - Cabinet Seal CF-8, CF-32, CF-16

1

2001-03-30

EMC Cabinet Seal CF 8, CF 16, CF 32.

Cabinet Seal CRST followed by 25, 31, 43 or 50.

Roxgland RG M63 followed by 1, 4 or 9.

USR, CNR - EzEntry series, Cat. No. 4 mini, 4 10, 16,
24 32USR, CNR - EMC Cabinet Seal, Cat. No. COMSEAL followed
by 10, 12, 15, 16, 30, or 32, followed by EMC**USR, CNR - Cabinet Seal, Cat. No. COMSEAL followed by
10, 12, 15, 16, 30, or 32.**

DESCRIPTION

PRODUCT COVERED:

Component - Industrial Control Panel Enclosures.

USR, CNR - Cabinet Seal CF-8, CF-32, CF-16

USR, CNR - EMC Cabinet Seal CF 8, CF 16, CF 32.

USR, CNR - Cabinet Seal CRST followed by 25, 31, 43 or 50.

USR, CNR - Roxgland RG M63 followed by 1, 4 or 9.

USR, CNR - EzEntry series, Cat. No. 4 mini, 4 10, 16, 24 32

USR, CNR - EMC Cabinet Seal, Cat. No. COMSEAL followed by 10, 12, 15, 16, 30, or 32, followed by EMC.

USR, CNR - Cabinet Seal, Cat. No. COMSEAL, followed by 10, 12, 15, 16, 30, or 32.

GENERAL:

These devices are constructed in accordance with the Standard for Industrial Control Equipment, UL 508, and with the construction as described pertaining to the particular device in this Report.

RATINGS:

Cat. No	Suitable for mounting on the flat surface of an Enclosure with the following Type ratings
Cabinet Seal CF-8, CF-32, CF-16 EMC Cabinet Seal CF 8, CF 16, CF 32. Cabinet Seal CRST followed by 25, 31, 43 or 50. Roxgland RG M63 followed by 1, 4 or 9.	4, 4X, 12 and/or 13
EzEntry Cat. No. 4 10, 16, 24 32	4, 4X, 12 and/or 13
EzEntry Cat. No. 4 mini	12 and/or 13
EMC cabinet seals, Cat. No. ComSeal, followed by 10, 12, 15, 16, 30, or 32, followed by EMC. Cabinet Seal, Cat. No. ComSeal followed by 10, 12, 15, 16, 30, or 32.	12 or 12K

MARKING:

Recognized Company's name and model number.

Suitable for mounting on the flat surface of an enclosure rated: (Type ratings as shown in the preceding table).