



# Certificate of constancy of performance

0402 - CPR - SC1479-11

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

## **ROXTEC MODULAR PENETRATION SEALING SYSTEM**

**penetration sealing system for cables in flexible and rigid wall constructions and rigid floor constructions. Fire resistance classes EI 60, EI 90 and EI 120 in accordance to EN 13501-2. Use category X and Z<sub>2</sub>.**

produced by or for

**Roxtec International AB**  
**Box 540**  
**SE-371 23 Karlskrona**  
**Sweden**

and produced in the manufacturing plant

**Roxtec International AB, Rombvägen 2, SE-371 65 Lyckeby, Sweden**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the ETA

**ETA 11/0313**

under system 1 for the performances set out in this certificate are applied and that

**the construction product fulfils all the prescribed requirements for these performances.**

This certificate was first issued on 2011-12-20 (under the Constructions Products Directive) and will remain valid as long as the ETA remains valid and the manufacturing conditions in the plant or the factory production control itself are not modified significantly, unless suspended or withdrawn by the product certification body.

2015-07-08

**SP Technical Research Institute of Sweden**  
**Certification, Notified Body No. 0402**

Lennart Månsson  
Certification Manager

Per Adolfsson  
Certification officer